



Tiivistelmä Pelastusviranomaisen ohjeesta (13.7.2017) nestekaasun käytöstä yleisötilaisuuksissa

Suurissa yleisötilaisuuksissa saa säilyttää ainoastaan sillä hetkellä käyttöön tarvittavan määrän nestekaasua.

On käytettävä pääsääntöisesti noin **5 kg:n** nestekaasupulloja. **Komposiittipullojen käyttöä suositellaan.** Myyntipaikalla (esim. ruokakoju 4x4 metriä) saa lähtökohtaisesti olla enintään 25kg nestekaasua. **Kaikkien tapahtuma-alueella olevien nestekaasupullojen on oltava kytkettyinä käyttölaitteisiin. Mahdolliset varapullot ja tyhjät pullot säilytetään toisaalla, asianmukaisesti varastoituna.**

Myyntipaikkaan, jossa käytetään nestekaasua, on sijoitettava yksi vähintään 6kg 27A 144B C käsisammutin ja sammutuspeite.

Käyttölaitteiden on oltava CE-merkittyjä ja käyttötarkoitukseensa soveltuvia. Käyttölaitteissa tulee olla sopiva paineensäädin sekä takaisinvirtauksen estävä letkurikkoventtiili.

Jos käyttölaitteen liittämiseen käytetään kaasulettoa, on letkun oltava nestekaasukäyttöön ja kohteen suurimmalle sallitulle käyttöpaineelle tarkoitettu. **Nestekaasuletkun pituus saa olla enintään 1,2 metriä. Letkun haaroittaminen on kielletty lukuunottamatta valmiin käyttölaitteen sisäisiä haaroituksia.**

Nestekaasun kiinteitä käyttölaitteita saa asentaa ja huoltaa vain Turvallisuus- ja kemikaaliviraston (TUKES) hyväksymä asennus-, huolto- ja tarkastusliike

SAFETY INSTRUCTIONS IN NUTSHELL FOR MARKET SELLERS 2019

These instructions are based on government's legislation and rules, regulations and recommendations of safety authorities

Liquefied petroleum gas LPG

In big public events it is allowed to store only LPG amount that is momentarily needed for use.

It is allowed to have in maximum 25 kg gas simultaneously in use at sales tent (e.g. 4x4 m). **Recommended are small bottles, preferably 5 kg composite bottles. All bottles must be connected to consumers (each to its own). Empty and refill bottles shall be stored elsewhere according to the safety rules of storing.**

All LPG equipment must be of approved type, adequate to their purpose and CE marked.

Hose length is 1,2 m at maximum and using of T-branches is not allowed except the ones originally assembled on the gear by the manufacturer.

All posts using LPG must be fitted with at least one 6 kg 27A 144B C fire extinguisher and a fire blanket.

To mount and service fixed LPG equipment is only allowed by companies approved by Finnish Safety and Chemicals Agency (Tukes)